

TEST REPORT**IEC 60 898-1:2002****Circuit-Breakers for over current protection for
household and similar installation**

Report reference No.	03601-A-14CB0007-S-B
Tested by (printed name and signature)	Dai Weiqiang
Approved by (printed name and signature)	Hu Delin
Date of issue	2014-04-29
CB Testing Laboratory Name	Suzhou Electrical Apparatus Science Research Institute Stock Co., Ltd.(EETI)
Address	No.7 Yonghe Street, Binhe Road, New District, Suzhou, China
Testing location /procedure	CBTL ☒ TMP ☐ WMT ☐ SMT ☐
Address Testing Location.....	
Applicant's Name	Zhejiang Tengen Smart Electrics Co., Ltd.
Address	No. 2777 West Zhongshan Road,Xiuzhou District,Jiaxing, Zhejiang Province,P.R.China
Test specification:	
Standard	IEC 60898-1:2002 + Amendment 1:2002
Test procedure	CB / CCA
Procedure deviation	
Non-standard test method	
Test Report Form	
Test Report Form No.....	IEC60898_1B
TRF originator	KEMA
Master TRF	dated 2004-02
Copyright © 2004 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.).	
Test item description	Miniature Circuit-Breaker
Trademark	Tache
Manufacturer	Zhejiang Tengen Smart Electrics Co., Ltd.
Series	/
Model and/or type reference	THB1C-63
Rating(s)	Ue: AC400V; In: 6A,10A,16A,20A,25A,32A,40A,50A,63A; Type:C, D; Ics=Icn:6kA; 2P.

TRF originator: KEMA